

NORTH ATTLEBOROUGH WATER DIVISION

2025 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources

Sample Collection Date	Water Treatment Plant	Whiting Treatment- with Highway Well - 10032	Whiting Treatment- No Highway Well- 10031 (Sampling not required)	McKeon Treatment	Hillman Well	KIOSK - Vending Unit Removed from Service	Adamsdale Well	MCL (ng/L)
	EPTDS	Whiting Street	Whiting Street	Mary Kennedy Dr.	Huntsbridge Road	Whiting Street	Grandview Drive	
1/27/2025	January	12.2	na	not detected	11.0	not detected	not detected	20
2/21/2025	February	11.7	na	not detected	14.0	not detected	not detected	
3/19/2025	March	11.3	na	not detected	13.5	not detected	not detected	
	Quarterly Average	11.7			12.8			
4/07/2025	April	12.7	na	not detected	14.0	na	not detected	20
5/19/2025	May	11.2	na	not detected	well offline to system	na	not detected	
	June							
	July							20
	Aug							
	September							
	October							20
	November							
	December							
	Average							

KEY:

EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system) ng/L = nanograms per liter, also equal to parts per trillion (ppt)

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

NOTES:

Yellow highlight = Violation

not detected - PFAS below 2.0 ppt - lowest concentration that can be detected

Violation/compliance with regulation based on locational Quarterly Averages Adamsdale Well is currently an inactive source