

NORTH ATTLEBOROUGH WATER DIVISION								
2024 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources								
Sample Collection Date	Water Treatment Plant	Whiting Treatment- with Highway Well - 10032	Whiting Treatment- No Highway Well- 10031 (Sampling not required)	McKeon Treatment	Hillman Well	KIOSK - Vending Unit	Adamsdale Well	MCL (ng/L)
	EPTDS	Whiting Street	Whiting Street	Mary Kennedy Dr.	Huntsbridge Road	Whiting Street	Grandview Drive	
1/18/2024	January	18.4	na	16.3	15.3	not detected	not detected	20
2/15/2024	February	15.3	n/a	16.9	14.6	not detected	not detected	
3/11/2024	March	14.6	n/a	17.3	16.8	not detected	not detected	
		16.1	n/a	16.8	15.6	not detected	not detected	
					</			