

NORTH ATTLEBOROUGH WATER DIVISION								
2024 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources								
Sample Collection Date	Water Treatment Plant	Whiting Treatment- with Highway Well - 10032	Whiting Treatment- No Highway Well- 10031 (Sampling not required)	McKeon Treatment	Hillman Well	KIOSK - Vending Unit	Adamsdale Well	MCL (ng/L)
	EPTDS	Whiting Street	Whiting Street	Mary Kennedy Dr.	Huntsbridge Road	Whiting Street	Grandview Drive	
1/18/2024	January	18.4	na	16.3	15.3	not detected	not detected	20
2/15/2024	February	15.3	n/a	16.9	14.6	not detected	not detected	
3/11/2024	March	14.6	n/a	17.3	16.8	not detected	not detected	
		16.1	n/a	16.8	15.6	0	0	
4/08/2024	April	12.8	n/a	13.9	12.9	not detected	not detected	20
5/03/2024	May	13.6	n/a	13.5	13.3	not detected	not detected	
6/10 - 6/14	June	15.2	n/a	18.7	19.7	not detected	not detected	
		13.9	n/a	15.4	15.3	0	0	
	Quarter 4 Averages						-	

KEY:

EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system) ng/L = nanograms per liter, also equal to parts per trillion (ppt)

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

NOTES:

Yellow highlight = Violation

Red highlight=Offline from system

Violation/compliance with regulation based on locational Quarterly Averages Adamsdale Well is currently an inactive source