

NORTH ATTLEBOROUGH WATER DIVISION
2025 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources

| Sample Collection Date | Water Treatment Plant | Whiting Treatment- with Highway Well - 10032 | Whiting Treatment- No Highway Well- 10031 (Sampling not required) | McKeon Treatment | Hillman Well | KIOSK - Vending Unit Removed from Service | Adamsdale Well | MCL (ng/L) |
|------------------------|--------------------------|--|---|---------------------|------------------------|---|---------------------|------------|
| | EPTDS | Whiting Street | Whiting Street | Mary Kennedy Dr. | Huntsbridge Road | Whiting Street | Grandview Drive | |
| 1/27/2025 | January | 12.2 | na | not detected | 11.0 | not detected | not detected | 20 |
| 2/21/2025 | February | 11.7 | na | not detected | 14.0 | not detected | not detected | |
| 3/19/2025 | March | 11.3 | na | not detected | 13.5 | not detected | not detected | |
| | Quarterly Average | 11.7 | | not detected | 12.8 | | not detected | |
| 4/07/2025 | April | 12.7 | na | not detected | 14.0 | na | not detected | 20 |
| 5/19/2025 | May | 11.2 | na | not detected | well offline to system | na | not detected | |
| 6/17/2025 | June | 12.3 | na | not detected | 14.1 | na | not detected | |
| | Quarterly Average | 12.1 | | not detected | 14.1 | | not detected | |
| 7/28/2025 | July | 14.3 | na | not detected | 17.0 | na | not detected | 20 |
| 8/25/2025 | Aug | 11.5 | na | not detected | 14.6 | na | not detected | |
| 9/18/2025 | September | 12.5 | na | not detected | 16.3 | na | not detected | |
| | Quarterly Average | 12.7 | | not detected | 15.9 | | not detected | |
| 10/25/2025 | October | 12.9 | na | not detected | 16.3 | na | not detected | 20 |
| 11/20/2025 | November | 11.9 | na | not detected | 16.8 | na | not detected | |
| | December | | | | | | | |
| | Average | | | | | | | |

KEY:
EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system) ng/L = nanograms per liter, also equal to parts per trillion (ppt)
MCL = Maximum Contaminant Level (highest amount allowed by regulation)
QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons
NOTES:
Yellow highlight = Violation
not detected - PFAS below 2.0 ppt - lowest concentration that can be detected
Violation/compliance with regulation based on locational Quarterly Averages Adamsdale Well is currently an inactive source